WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81648
Permit No.
Basin 101

NOTICE OF INTENT NO. 44172

1. OWNER Hawk Properties
MAILING ADDRESS 2161 W Williams Ave PMB 280
Fallon, NV 89406-2612

ADDRESS AT WELL LOCATION 4410 Hawk Drive, Fallon, NV 89406

2. LOCATION NE 1/4 NE 1/4 Sec. 28 T 19N N/S R 28E E Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 8-281-74 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	10	10
Brown Sand		10	18	8
Brown Clay		18	22	4
Brown Sand		22	34	12
Gray Clay		34	50	16
Brown sand	XX	50	65	15

RECEIVED 2000 OCT 30 PM 1:47 STATE ENGINEER'S OFFICE

Date started 08/02/2000 , 19__
Date completed 08/02/2000 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1hr

8. WELL CONSTRUCTION
Depth Drilled 65 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	65	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	10
6 PVC	3.92	.258	10	65

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 63 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 65 feet

9. WATER LEVEL
Static water level 14.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on-site or contractor)
Date 10/23/2000

USE ADDITIONAL SHEETS IF NECESSARY