WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81685
Permit No.
Basin 100

NOTICE OF INTENT No. 44900 44901

1. OWNER Jeffery P Picciotta
MAILING ADDRESS Box 336
Gardnerville Nv

ADDRESS AT WELL LOCATION
1521 Moss Circle
Gardnerville Nv

2. LOCATION SE ¼ NW ¼ Sec. 18 T. 10 N/S R. 22 E Douglas County
PERMIT NO. (Issued by Water Resources) 37501-120 (Parcel No.) Holbrook Highlands (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Andesite Rubble | | 0 | 65 | 65 |
| " Boulders Large | | 65 | 72 | 7 |
| Andesite Rubble w/ Clay | | 72 | 104 | 32 |
| Broken & Fractured Andesite | | 104 | 175 | 71 |
| Andesite Rubble w/ Clay | | 175 | 210 | 35 |
| Fractured Andesite | | 210 | 263 | 53 |
| Broken Rubble w/ Clay | | 263 | 290 | 27 |
| Fractured Andesite | ✓✓ | 290 | 320 | 30 |

Date started 8-14 00
Date completed 8-29 00

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Air | 30 | | 2 hrs |

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 60 Feet |
| 9 7/8 Inches | 60 Feet | 320 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 17 | .188 | +2 | 320 |

Perforations:
Type perforation Factory Milled
Size perforation 1/8 x 3
From 290 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon, Nv 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1596
Signed (By driller performing actual drilling on site or contractor)
Date 8-30-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627