WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81747
Permit No.
Basin 49

NOTICE OF INTENT NO. 4200

1. OWNER SALVADOR RODRIGUEZ
MAILING ADDRESS BOX 6475
ELKO, NV 89802

ADDRESS AT WELL LOCATION None

2. LOCATION SE ¼ NW ¼ Sec. 3 T. 35 (N)/S R. 56 (E) ELKO County
PERMIT NO. (Issued by Water Resources) 035-14-009 (Parcel No.) Meadow Valley Ranchos Unit #3 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	2	2
Clay, sand, gravel		2	9	7
Sandy clay		9	70	61
water	seep		70	
Sandy clay		70	100	30
Thin layers of sand & gravel separated by clay	6gpm	100	130	30
"	~~[illegible]~~	~~[illegible]~~		
"	18gpm	130	180	50
T.D. 180				

RECEIVED SEP 13 AM 10:50 STATE ENGINEER

Date started 7-17-2000, 19
Date completed 8-10-2000, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	50	2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 181 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	180 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	80
5 9/16	12.59	.219	80	180

Perforations:
Type perforation Torch cut
Size perforation 1/8 x 6" x 2 Rt.
From feet to feet
From 100 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MUTH DRILLING CO. (Contractor)
Address 203 PINE ST. (Contractor)
ELKO, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth (By driller performing actual drilling on site or contractor)
Date 9-6-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627