WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81857
Permit No.
Basin

NOTICE OF INTENT NO. 44220

1. OWNER Frank Woosley
MAILING ADDRESS 2161 W Williams Pdb 280
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4265 Raven Dr Fallon Nv. 89406

2. LOCATION NE 1/4 NE 1/4 Sec. 28 T 19 N/S R 28 E Churchill County
PERMIT NO. Issued by Water Resources | 00828160 Parcel No. | Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Brown Sand		15	50	35
Gray Sand		50	57	7
BRown Sand	xx	57	65	8

RECEIVED
OCT 17 2000
STATE ENGINEER'S OFFICE

Date started 04/13/2000, 19__
Date completed 04/13/2000, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 hr

8. **WELL CONSTRUCTION**
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	65	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	10
6 pvc	3.92	.258	10	65
			65	

Perforations:
Type perforation saw cut
Size perforation 1/8
From 62 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 65 feet

9. **WATER LEVEL**
Static water level 13 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1264 Contractor
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on-site or contractor
Date 04/17/2000

USE ADDITIONAL SHEETS IF NECESSARY