WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

4PA

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81987
Permit No.
Basin 230

NOTICE OF INTENT NO. ~~20147~~ 22344
JPC

1. OWNER NYE COUNTY
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec. 12 T. 15S N/S R. 49 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other HAMMER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELY SANDS WITH		0	25	25'
FINE SANDS AND				
COARSE GRAVEL				
		25	255	230'
GRAVELLY SAND PREDOM				
FINE GRAVEL COARSE				
MED SAND PALE ORANGE				
BASALT AT 48'				
		255	275	20'
GRAVELY SAND WITH				
SOME CLAY				
		275	350'	75'
GRAVELY SAND WITH CLAY				
AND FINE GRAVELS				
		350'	390'	40'
GRAVELY SAND WITH CLAY				
PREDOM FINE GRAVEL.				
		400	420	20'
SANDY CLAY FINE SAND				
MED PLASTICITY PALE				
YE BRN		420	500	80'
THIN SAND CLAY				
FINE SAND CLAY				
MED PLASTICITY				

DCNR/DWR Received NOV 7 2000 LAS VEGAS OFFICE

Date started 7 JAN, 19 2000
Date completed 18 JAN, 19 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	20/30	6 HRS

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 497 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 3/4 Inches		0 Feet	500 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 7/8"	6 LBS		0	497

Perforations:
Type perforation SLOTTED
Size perforation .020
From 497 feet to 407 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 497 feet to 395' feet

9. WATER LEVEL
Static water level 334 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 64 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JOEL CAMPBELL (Contractor)
Address LAYNE CHRISTENSEN (Contractor)
12030 E RIGGS RD CHANDLER
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1813
Signed Joel Campbell (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627