

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 81932  
 Permit No. 162  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20781

1. OWNER Nationwide Homes ADDRESS AT WELL LOCATION 6450 S. Quarterhorse  
 MAILING ADDRESS 6450 S. Quarterhorse  
Pahrump, NV 89060

2. LOCATION NE 1/4 NE 1/4 Sec. 18 T 21S N/S R 54E E Nye County Nye  
 PERMIT NO. 45-227-08 Parcel No. Charlotta Estates Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown loam</u>		<u>0</u>	<u>18</u>	<u>18</u>
<u>See next line</u>	<u>x</u>	<u>18</u>	<u>121</u>	<u>103</u>
<u>brown loam with caleche strings</u>				
<u>brown loam</u>	<u>x</u>	<u>121</u>	<u>126</u>	<u>5</u>
<u>brown loam with gravel</u>	<u>x</u>	<u>126</u>	<u>140</u>	<u>14</u>

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation sawcut  
 Size perforation .188

From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet



Date started 12/5/00 19  
 Date completed 12/5/00 19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level 58 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Romy Strickland  
 By driller performing actual drilling on-site or contractor  
 Date 12-7-00

