

OFFICE USE ONLY  
 Log No. 8195 PL  
 Permit No. 212  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21612

1. OWNER PBS Decatur, LLC ADDRESS AT WELL LOCATION 4840 S. Decatur  
 MAILING ADDRESS 5166 Rogers Street Las Vegas, NV 89118  
 2. LOCATION SW 1/4 SW 1/4 Sec. 19 T. 21 N. OR 61 E Clark County  
 PERMIT NO. 1162-19-401-01 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Gravelly SAND		0	8	8
Silty SAND		8	13	5
Sandy SILT		13	18	5
Clayey SILT		18	24	6
Cariche		24	27	3
Clayey SILT		27	34	7
Cariche		34	37	3
Sandy, Clayey SILT		37	45	8

8. WELL CONSTRUCTION  
 Depth Drilled 45 Feet Depth Cased 42 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6.5 Inches To 45 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
Schedule 40				

Perforations:  
 Type perforation slotted  
 Size perforation 0.020  
 From 32 feet to 42 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

\* Well was abandoned by drilling out/ removing casing + backfilling with a concrete grout



Date started Nov 16 2000  
 Date completed Nov 16 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 35.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Western Technologies Contractor  
 Address 3611 W. Tompkins Ave Contractor  
Las Vegas, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board M1761  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller \_\_\_\_\_  
 Signed [Signature]  
 Date 12/01/00