

OFFICE USE ONLY
 Log No. 82041
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20958

1. OWNER Contri Const. Co ADDRESS AT WELL LOCATION Home Depot parking lot
 MAILING ADDRESS Las Vegas

2. LOCATION S 1/4 NW 1/4 Sec 3 T 21 N 10R 60E Clark County
 PERMIT NO. DW 1116 Issued by Water Resources Parcel No. 1161-05-201-003 Subdivision Name _____

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other D/W

4. PROPOSED USE: Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE: Cable Rotary RVC Air Other Rock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>0-2 fill</u>		<u>0</u>	<u>2</u>	
<u>5 silty clay</u>		<u>0</u>	<u>18</u>	
<u>Sandy clay w/ silts</u>		<u>18</u>	<u>40</u>	
<u>Sand & gravel in silty clay</u>		<u>40</u>	<u>55</u>	

3 wells in this parcel
 other 2 only 45' deep

8. WELL CONSTRUCTION
 Depth Drilled 55 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)
 From 2.4 Inches To 4.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>45</u>

Perforations:
 Type perforation Slot
 Size perforation .030

From _____ feet to _____ feet
 From 15 feet to 45 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout

Depth of Seal _____

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 14 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 1-16-01, 19____
 Date completed 1-17-01, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Griffin Downton Contractor
 Address 536 E. Mainland Contractor
Orlando CA

Nevada contractor's license number issued by the State Contractor's Board 31246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1968

Signed [Signature]
 Date 1-24-01