WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82057
Permit No.
Basin 212

NOTICE OF INTENT NO. 19167

1. OWNER Parsons Brinckerhoff Douglas & Quade
MAILING ADDRESS 3930 Howard Hughes Pky #300 LV. NV. 89109

ADDRESS AT WELL LOCATION 150' West of Rancho Dr. in East bound Left Turn Lane of Charleston

2. LOCATION N.E. ¼ N.E. ¼ Sec. 5 T. 21S N/S R. 61 E. CLARK County

PERMIT NO. ____ Issued by Water Resources | ~~162-05-500-001~~ Parcel No. | — Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Gravel		0	2	2
Clayey Sand		2	3½	1½
Silty Clay		3½	7	3.5
Clayey Gravel		7	10½	3.5
Caliche		10½	12½	2.0
Clayey Sand	W	12½	14	1.5
Silty Clay		14	21	7
Caliche		21	22½	1½
Sandy Clay		22½	24	1½
Sandy Gravel		24	27	3
Silty Sand		27	30	3

DOWNHOWE Received JAN 31 2001 LAS VEGAS OFFICE

Date started 1-16-2000 01, ~~19~~
Date completed 1-16-2000 01, ~~19~~

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 29.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6.5 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Sch 40	0.5	29.5

Perforations:
Type perforation Slotted screen
Size perforation .020-inch
From 9.5 feet to 29.5 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 30 feet

9. WATER LEVEL
Static water level 12' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants
Contractor
Address 4343 S. Polaris Ave
Contractor
LV. NV. 89103

Nevada contractor's license number issued by the State Contractor's Board ____
Nevada driller's license number issued by the Division of Water Resources, the on site driller 2097
Signed [signature]
By driller performing actual drilling on site or contractor
Date 1-24-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627