WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82113
Permit No.
Basin 103

NOTICE OF INTENT NO. 44909

1. OWNER Wahl To Wahl Construction
MAILING ADDRESS 881 Mahogany Drive
Minden, NV 89423

ADDRESS AT WELL LOCATION 704 Winners Circle
Gardnerville, Nv. 89410

2. LOCATION NE 1/4 SW 1/4 Sec. 24 T 12N N/S R 20E E Douglas County
PERMIT NO. Issued by Water Resources
1220-24-3020-031 Parcel No.
Ruhenstroth Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay	no	0	23	23
Unsorted sand and	no	23		
Gravel			67	44
Clay and sandy Clay	no	67	86	19
med. sorted gravel and	yes	86		
sand			165	79

RECEIVED
00 DEC 12 AM 11:19
STATE ENGINEER'S OFFICE

Date started 11/28/2000 , 19__
Date completed 12/5/2000 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2hrs

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	60	Feet
9 7/8	Inches	60	Feet	165	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	165

Perforations:
Type perforation Factory Milled
Size perforation 1/16x3 6 row
From 145 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50ft
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 78ft. feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc. Contractor
Address 7780 Curry Rd. Contractor
Fallon, Nv. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] By driller performing actual drilling on-site or contractor
Date 12/10/2000

USE ADDITIONAL SHEETS IF NECESSARY