COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82128
Permit No.
Basin 103

NOTICE OF INTENT NO. 42003

1. OWNER RICK DECARLO CUSTOM HOMES
MAILING ADDRESS P.O. BOX 2844
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 1572 SAWMILL RD
GARDNERVILLE, NV 89410

2. LOCATION SE ¼ SE ¼ Sec 26 T 13 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | 13320-35-001-033 (Parcel No.) | WILDFLOWER AREA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	4	4
HARD PAN CLAY		4	8	4
COURSE SAND AND		8	37	29
COBBLES				
COUSE GRAVELS		37	86	49
INBEDED GRAVELS				
BROWN CLAY		86	178	92
GUMMY BROWN CLAY		178	227	49
STRATA				
BROKEN STRATA OF	XXX	227	260	33
GRAVELS & OBSIDIAN				
SANDS AND GRAVELS				

Date started 9/8, 20 00
Date completed 9/10, 20 00

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	45	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 260' Feet Depth Cased 260' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	260' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	260'

Perforations:
Type perforation MILL SLOT FACTORY CUT
Size perforation 3 3/32
From 240' feet to 260' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 260 feet

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M 30 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMPS (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature]
By driller performing actual drilling on site or contractor
Date 9/11/00