WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82162
Permit No.
Basin 92A

NOTICE OF INTENT NO. 45038

1. OWNER ANN GIBSON
MAILING ADDRESS 1215 Columbia Hill Road
Reno, Nevada 89506

ADDRESS AT WELL LOCATION
Same

2. LOCATION NW ¼ NW ¼ Sec. 6 T 21N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 079-331-03 (Parcel No.) Red Rock Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil & gravel & boulder		0	1	1
Brown sandy clay		1	12	11
Brown sand		12	13	1
Brown sandy clay		13	40	27
Soft zone, brown sand		40	42	2
Brown sandy clay		42	91	49
Soft zone, granite coarse sand		91	93	2
Brown sandy clay		93	163	70
Soft zone		163	165	2
Brown sandy clay		165	251	86
Soft zone(NO WATER)		251	253	2
Brown sandy clay		253	298	45
Soft zone, coarse sand		298	310	12
Brown clay		310	318	8
Coarse to medium sand with clay streaks	X	318	360	42
Brown sandy clay		360	365	5

Date started October 12, 2000, 19
Date completed October 16, 2000, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		

8. WELL CONSTRUCTION
Depth Drilled 365 Feet Depth Cased 365 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet	
8 5/8 Inches	50 Feet	365 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	365

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 300 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 365 feet

9. WATER LEVEL
Static water level 298 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date October 19, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627