WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82220
Permit No.
Basin 104

NOTICE OF INTENT NO. 43578

1. OWNER R.M. & Diana Howard
MAILING ADDRESS 1679 Valley View Road
Carson City, Nevada 89701

ADDRESS AT WELL LOCATION 1679 Valley View Road Carson City, Nevada 89701

2. LOCATION SE ¼ SW ¼ Sec. 28 T 15N N/S R 20E E Carson City County
PERMIT NO. R-373 (Issued by Water Resources) 010-182-16 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~~Try to install perforator in casing perforator will only go to 15 feet due to size and condition of casing, contacted division of water resources and informed them of this and a waiver was granted to waive perforating of casing. Install trimie pipe to total depth and pump approx 2500 lbs of neat cement to top of casing to abandon well~~				
T.D. 87				

Date started 8-21-2000, 19
Date completed 8-21-2000, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
dry		

8. WELL CONSTRUCTION
Depth Drilled 87 Feet Depth Cased 87 Feet

HOLE DIAMETER (BIT SIZE)
Inches From Feet To Feet
Inches From Feet To Feet
Inches From Feet To Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
~~6~~				

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal in place
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level dry feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service (Contractor)
Address P.O. Box 60130 (Contractor)
Reno, Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 0035387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed (By driller performing actual drilling on site or contractor)
Date 9-19-2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627