WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82293
Permit No.
Basin 162

NOTICE OF INTENT NO. 19113

1. OWNER CAMERON
MAILING ADDRESS 5721 E DOUBLETREE
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 5721 E DOUBLETREE

2. LOCATION NW 1/4 SE 1/4 Sec. 16 T 21S N/S R 54E E NYE County
PERMIT NO. _____ Issued by Water Resources | 43-091-12 Parcel No. | COTTONWOODS Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0	88	88
GRAVEL	WB	88	101	13
CLAY		101	115	14
GRAVEL	WB	115	128	13
CLAY		128	135	7
CALICHIE	WB	135	140	5

DCNR/DWR Received FEB 21 2001 LAS VEGAS OFFICE

Date started 1/29/2001, 19__
Date completed 1/30/2001, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	140

Perforations:
Type perforation SAW CUT
Size perforation 1/8 X 3
From 100 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor

Address P.O. BOX 4220
Contractor

PAHRUMP,NV. 89048

Nevada contractor's license number issued by the State Contractor's Board 47333

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063

Signed Thomas Dan
By driller performing actual drilling on-site or contractor

Date 1/30/2001

USE ADDITIONAL SHEETS IF NECESSARY