WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82299
Permit No.
Basin 212

NOTICE OF INTENT NO. 21373

1. OWNER Clark County Department of Aviation
MAILING ADDRESS P.O. Box 11005
Las Vegas, NV 89111

ADDRESS AT WELL LOCATION 4811 South Paradise Road, Las Vegas, NV 89109

2. LOCATION SW 1/4 SW 1/4 Sec. 22 T 21S N/S R 61E E Clark County
PERMIT NO. 1126 (Issued by Water Resources) 162-22-401-002 (Parcel No.) IW-1 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan Silty Sand		0	12	12
Caliche		12	17	5
Greyish Tan Silty Sand		17	33	16
Silty Clay		33	35	2

1 of 2

Well 1

DCNR/DWR Received FEB 20 2001 LAS VEGAS OFFICE

Date started 01/26/2001, 19__
Date completed 01/26/2001, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	32	Feet
4.25	Inches	32	Feet	35	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.00	0.24	0	30

Perforations:
Type perforation Factory Slotted PVC
Size perforation 0.020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-5; 5-8 Bentonite
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 8 feet to 35 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don Wilson c/o Converse Consultants
Contractor

Address 731 Pilot Road, Suite H
Contractor

Las Vegas, NV 89119

Nevada contractor's license number issued by the State Contractor's Board 48947

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 02/07/2001

I

USE ADDITIONAL SHEETS IF NECESSARY