WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82328
Permit No.
Basin 212

NOTICE OF INTENT NO. 21517

1. OWNER CLARK COUNTY SANITATION DISTRICT
MAILING ADDRESS 5857 E. FLAMINGO RD.
LAS VEGAS, NV 89122

ADDRESS AT WELL LOCATION 5857 E. FLAMINGO RD.
LAS VEGAS, NV 89122

2. LOCATION NW ¼ NW ¼ Sec. 22 T. 21 N/S R. 62 E CLARK County
PERMIT NO. DW-1127 (Issued by Water Resources) 161-22-101-001 (Parcel No.) CCSD Primary Station #404 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [X] ~~Other MONITOR~~

4. Dewater PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ~~6 Monitor wells~~ of 20 Dewater | | | | |
| Sandy Clay | | 0 | 8' | 8' |
| Silt | X | 8' | 12' | 4' |
| Silt/Gray clay | XX | 12' | 40' | 23' |

Date started 1/16/2001, 19
Date completed 2/5/2001, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 40' Feet Depth Cased 40' Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 24" | Inches | 0 | Feet | 40 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | 36.71 | 0250 | 0 | 40 |
| | | | | |

Perforations: Machine:
Type perforation
Size perforation 1/4 x 2 1/2x
From 0 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [ ] No
Depth of Seal
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2117
Signed (By driller performing actual drilling on site or contractor)
Date 2-23-01

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627