

OFFICE USE ONLY
 Log No. 82379
 Permit No. 102
 Basin. 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT TO 43097
4095 E. 10th St

1. OWNER David & Marie Davino ADDRESS AT WELL LOCATION Silver Springs, Nev 89429
 MAILING ADDRESS P.O. Box 1069
Silver Springs, NV 89429
 2. LOCATION SW 1/4 NW 1/4 Sec. 15 T. 17 N. S. R. 25 E. LYON County
 PERMIT NO. 17-383-02 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Brown Sand</u>		<u>0</u>	<u>40</u>	<u>40</u>
<u>Gray Sand</u>	<u>*</u>	<u>40</u>	<u>70</u>	<u>30</u>
<u>Gray Clay</u>		<u>70</u>	<u>75</u>	<u>5</u>
<u>Gray Sand</u>		<u>75</u>	<u>102</u>	<u>27</u>
<u>Large white Brown Sand</u>		<u>102</u>	<u>120</u>	<u>18'</u>

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>188</u>	<u>72</u>	<u>100</u>

Perforations:
 Type perforation MILL SLOT
 Size perforation 2/32
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 120 feet

Date started 1-15-2001
 Date completed 1-16-2001, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air Lift</u> <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>Total</u>	<u>2</u>

9. WATER LEVEL
 Static water level 42 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Pump Service Contractor
 Address P.O. Box 2227 Contractor
Dayton, Nev 89403
 Nevada contractor's license number 0096357
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1790
 Division of Water Resources, the on-site driller
 Signed Monty Lopez
 By driller performing actual drilling on site or contractor
 Date 1-31-01

RECEIVED
 01 FEB - 7 AM 11:24
 STATE ENGINEERS OFFICE