

OFFICE USE ONLY  
 Log No. 82,380  
 Permit No. 89  
 Basin I  
 NOTICE OF INTENT NO. 72256

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Robert + Chris Vaught ADDRESS AT WELL LOCATION Peppy Jan Court  
#1836 Reno, Nev 89511 Washoe Valley, Nev  
 2. LOCATION SW 1/4, SE 1/4 Sec 5 T 16 S R 20 E County Washoe  
 PERMIT NO. 6767 Wa. Co. 050-301-68 Park View Est  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG		0	20	20
S.H Brown Clay and Small Bubbles		20	121	101
Sand Small Gravels		121	138	17
Brown Clay		138	145	7
Decomposed Volcanic Rock		145	200	55

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 3/8 Inches To 0 Feet  
 From 0 Feet To 200 Feet  
 From 0 Feet To 0 Feet  
 From 0 Feet To 0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>182</u>	<u>72</u>	<u>120</u>
<u>6 3/8</u>		<u>158</u>	<u>140</u>	<u>180</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation .188 3/32  
 From 120 feet to 140 feet  
 From 150 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 60' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality N/A

Date started 1-24-01 1901  
 Date completed 1-26-01 1901

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Bailer	Pump	
<u>Air Lift</u>	<u>20+30</u>	<u>Total</u>	<u>3</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Nevada Pump Service Contractor  
 Address PO Box 2227 Contractor  
Dayton, Nev 89403  
 Nevada contractor's license number issued by the State Contractor's Board 0046357  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 79701790  
 Signed Monty Lopez  
 By driller performing actual drilling on site or contractor  
 Date 1-31-01