

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **82620**
 Permit No.
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20797

1. OWNER **CRHomes**
 MAILING ADDRESS **5600 N. Leslie Pahrump, NV 89048**

ADDRESS AT WELL LOCATION
5600 N. Leslie

2. LOCATION **SE 1/4 NE 1/4 Sec. 18 T 19S**
 PERMIT NO. **27-191-03**
 Issued by Water Resources Parcel No.

N/S R **53E** E **Nye** County
 Nye
 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown silty loam		0	14	14
brown loam		14	47	33
See next line	x	47	72	25
brown loam with caleche strings				
See next line	x	72	95	23
caleche with compacted gravel				
brown caleche	x	95	101	6
See next line	x	101	104	3
brown loam with caleche strings				
brown sandy loam with gravel	x	104	190	86

8. WELL CONSTRUCTION

Depth Drilled **190** Feet Depth Cased **160+1** Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
11 Inches	0 Feet	160 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From	feet to	feet
140	160	
From	feet to	feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **160** feet

9. WATER LEVEL
 Static water level **69** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date **2-28-01**



Date started **2/28/01** 19__
 Date completed **2/28/01** 19__

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

