WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82677
Permit No.
Basin 91

NOTICE OF INTENT NO. 35[illegible]

1. OWNER Verdi Meadows Utility Co.
MAILING ADDRESS 1129 Hunter Lake Dr #3
Reno, NV. 89509

ADDRESS AT WELL LOCATION County Rd. 109 & W. Hwy 40

2. LOCATION NW 1/4 SW 1/4 Sec. 9 T 19N N/S R 18 E Washoe County

PERMIT NO. _____ Issued by Water Resources
038-030-01 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	
clay w/sand		2	10	8
clay w/some small rock		10	13	3
clay w/sand & rock		13	21	8
sandy clay w/1inch gravel		21	24	3

Date started 12/27 2000
Date completed 12/27 2000

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 24.5 Feet Depth Cased 23.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6-1/4 Inches		0 Feet	24.5 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 id	sch. 40	pvc	0	18.5

Perforations:
Type perforation 2 pvc sch. 40
Size perforation .020
From 18.5 feet to 23.5 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 13
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 15 feet to 24.5 feet

9. WATER LEVEL

Static water level 10.31 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1572

Signed Terri A. Tomek
By driller performing actual drilling on-site or contractor

Date 1/10/01