WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82950
Permit No.
Basin 212

NOTICE OF INTENT NO. 20398

1. OWNER Contri Const.
MAILING ADDRESS L.V. NV.
ADDRESS AT WELL LOCATION On Olive St. West of Mason

2. LOCATION N NE ¼ Sec. 6 T. 21 N(S) R. 62 E Clark County
PERMIT NO. DW 1116 (Issued by Water Resources) 161-06-50-001 thru 042 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation (Dewatering) ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Bucket

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 18 wells | | | | |
| in these parcel | | | | |
| Areas | | | | |
| fill | | 0 | 3 | |
| Sandy Clay | | 3 | 13 | |
| Clay w/ silt | | 13 | 23 | |
| Sandy Clays w/ some gravel traces | | 23 | 35 | |
| | | 14 | | |

Date started 3-7-01, 19
Date completed 3-14-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 24 | 0 | 35 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | PVC | Sch 40 | 0 | 35 |
| | | | | |

Perforations:
Type perforation Slot
Size perforation .030
From feet to feet
From 5 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 35 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering (Contractor)
Address 536 E Maitland (Contractor)
Ontario CA
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968
Signed (By driller performing actual drilling on site or contractor)
Date 3-14-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627