

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **83050**  
 Permit No. **162**  
 Basin **I**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20811

1. OWNER **CRHomes**  
 MAILING ADDRESS **3451 Rebel Ave**  
**Pahrump, NV 89041**

ADDRESS AT WELL LOCATION  
**3451 Rebel Ave**

2. LOCATION **NE 1/4 SW 1/4 Sec. 32 T 20S**  
 PERMIT NO. **40-583-08**  
 Issued by Water Resources Parcel No.

**N/S R 53E E Nye** County  
**Calvada Valley** Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	27	27
See next line	x	27	80	53
brown clay with caleche strings				
brown clay	x	80	160	80

8. WELL CONSTRUCTION

Depth Drilled **160** Feet Depth Cased **160+1** Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
Inches	0	Feet 160	Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:  
 Type perforation **sawcut**  
 Size perforation **.188**

From <b>140</b>	feet to <b>160</b>	feet
From	feet to	feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50** Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **160** feet



9. WATER LEVEL

Static water level **64** feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature **cool** °F Quality **good**

Date started **4/21/01** .19\_\_  
 Date completed **4/21/01** .19\_\_

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor  
 Address **2301 Winery Road, Suite 2** Contractor  
**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **5.27.01**

