WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83066
Permit No.
Basin 162

NOTICE OF INTENT NO. 19135

1. OWNER Doug Richards
MAILING ADDRESS 2231 E. Dandelion St. Pahrump, NV 89048
ADDRESS AT WELL LOCATION 2231 E. Dandelion St. Pahrump, Nevada 89048

2. LOCATION NE ¼ NW ¼ Sec. 36 T. 20 N OR 53 E Nye County
PERMIT NO. — (Issued by Water Resources) | Parcel No. 41-011-10 | Subdivision Name Caluada Valley Unit 2

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt		0	20'	20'
white clay		20'	45'	25'
caliche		45'	50'	5'
white clay		50'	75'	25'
caliche		75'	85'	10'
white clay		85'	100'	15'
caliche		100'	105'	5'
brown clay		105'	125'	20'
granular caliche		125'	140'	15'
brown clay		140'	150'	10'
caliche		150'	155'	5'
brown clay		155'	163'	8'

Date started March 30, 2001
Date completed April 6, 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 163 Feet Depth Cased 163 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	163 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	140

Perforations:
Type perforation Saw Cut
Size perforation 1/8" x 3"
From 143 feet to 163 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 163 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lahue Construction Co. (Contractor)
Address 4191 S. Jackie St. (Contractor)
Pahrump, Nevada 89048
Nevada contractor's license number issued by the State Contractor's Board 0049225
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date May 2, 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627