WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83067
Permit No.
Basin 162

NOTICE OF INTENT NO. 19136

1. OWNER Bill & Coca Green
MAILING ADDRESS 9961 S. Raymond St. Pahrump, NV
ADDRESS AT WELL LOCATION 9961 S. Raymond St Pahrump, NV

2. LOCATION SE ¼ SE ¼ Sec. 35 T. 21 N/S R. 53 E. Nye County
PERMIT NO. Issued by Water Resources; Parcel No. 41-354-12; Subdivision Name Calunda Valley Unit 14

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy silt		0	10'	10'
caliche		10'	20'	10'
white clay		20	40'	20'
Sandy clay		40'	50'	10'
caliche		50'	55'	5'
brown clay		55'	80'	25'
Quartz		80'	90'	10'
white clay		90'	105'	15'
caliche		105'	110'	5'
brown clay		110'	115'	5'
caliche		115'	125'	10'
brown clay		125'	130'	5'
caliche		130'	135'	5'
brown clay		135'	140'	5'

Date started May 7, 2001
Date completed May 10, 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16.625	4.33	.316	0	140

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 3"
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LaRue Construction Co. (Contractor)
Address 4191 S. Jackie St. Pahrump, Nevada 89048 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0049225
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date May 21, 2001

MAY 29 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627