WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83128
Permit No. 55466
Basin 61

NOTICE OF INTENT NO. 38322

1. OWNER Barrick Goldstrike Mines - BW-9
MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike
Minesite, North of Carlin, NV.

2. LOCATION NE 1/4 SW 1/4 Sec. 24 T 36N N/S R 49 E Eureka County
PERMIT NO. 55466 Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial (mining) ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned per procedure discussed with DWR.				
Pour hole plug to 380', neat cement to 330', and backfill to surface.				
Quantities Used:				
Backfill: 583 cu.ft.		0	330	330
Cement: 120 cu.ft.		330	380	50
Hole plug: 2029 cu.ft.		380	1531	1151

Date started 11/23/2000 , 19__
Date completed 11/24/2000 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
32	Inches	0	Feet	38	Feet
25	Inches	38	Feet	1532	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
26	102.60	0.3750	0	38
18	70.59	0.3750	0	481
18	59.03	0.3125	481	1531

Perforations:
Type perforation Louver
Size perforation 0.125"
From 483 feet to 1522 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 1540 feet

9. WATER LEVEL
Static water level Dry feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2095
Signed Joe Crawford (By driller performing actual drilling on-site or contractor)
Date 12/5/00

USE ADDITIONAL SHEETS IF NECESSARY

B.ST.L