

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83175
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **44911**

1. OWNER Seward Homes ADDRESS AT WELL LOCATION 603 Stagecoach road
 MAILING ADDRESS P.O. Box 642 Gardnerville Nv.
Gardnerville, NV 89410

2. LOCATION SW 1/4 NE 1/4 Sec. 25 T 12N N/S R 20E E Douglas County
 PERMIT NO. 1220-25-510-007 ruhenstroth
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sandy clay and boulders	no	0	27	27
sand and gravel unsorted	27	27	127	100
cemented gravel Hard drilling	no	127	297	170
sand and gravel	yes	297	380	83

8. WELL CONSTRUCTION
 Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0	60
9 7/8 Inches	60	380

CASING SCHEDULE

Size O.D. (Inches)	Weight/FL (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	380

Perforations:
 Type perforation factory milled
 Size perforation 1/8 X4

From	To
<u>340</u> feet to	<u>380</u> feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet

Surface Seal: Yes No
 Depth of Seal 50ft
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 380 feet

9. WATER LEVEL
 Static water level 155 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eddco Explortion Inc Contractor

Date started 1/30/2001, 19__
 Date completed 2/22/2001, 19__

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>12</u>		<u>2hrs</u>

Address 7780 Curry Road Contractor
Fallon, Nv. 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 3/9/2001

RECEIVED
 01 APR - 2 AM 11:18
 STATE ENGINEERS OFFICE