WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83226
Permit No.
Basin 212

NOTICE OF INTENT NO. 21120

1. OWNER CLARK CO. SANITATION DISTRICT
MAILING ADDRESS 5857 EAST FLAMINGO RD
LAS VEGAS, NV. 89112

ADDRESS AT WELL LOCATION 5857 E. FLAMINGO RD
LAS VEGAS, NV 89112

2. LOCATION SW ¼ NE ¼ Sec. 22 T. 21 N/S R. 62 E. County
PERMIT NO. DW 1133 (Issued by Water Resources) 161-22-101-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE DEWATERING
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
28 WELLS				
BROWN SANDY CLAY		0	17	17
FINE SILTY SAND W/ BROWN SANDY CLAY LAYERS		17	38	21

RECEIVED
01 APR 27 PM 1:53
NEVADA DIVISION OF WATER RESOURCES

DCNR/DWR
Received
JUN 12 2001
LAS VEGAS OFFICE

Date started 2-27-01, 19
Date completed 4-2-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80	20	1

8. WELL CONSTRUCTION
Depth Drilled 38 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)
36 Inches From 0 Feet To 38 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33	.250	0	5

Perforations:
Type perforation LOUVERED
Size perforation .040
From 5 feet to 37 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 4
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout CLAY
Gravel Packed: ☒ Yes ☐ No
From 4 feet to 38 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name KELLEY DEWATERING & CONST. CO. (Contractor)
Address 5175 CLAY AVE. (Contractor)
WYOMING, MI. 49548
Nevada contractor's license number issued by the State Contractor's Board 50826-C23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS 2149
Signed [signature] By driller performing actual drilling on site or contractor
Date 4-23-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627