

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42658

1. OWNER Equilon Enterprises ADDRESS AT WELL LOCATION 199 HWY 50 Zephyr Cove, NV
 MAILING ADDRESS 6 Highlands Court Belmont CAL 94002-2918

2. LOCATION NE 1/4 SE 1/4 Sec 15 T 13 N R 18 E Douglas County
 PERMIT NO. NO-42658 05-290-010 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other man. way

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other SANIT.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill Material	NO	0'	13'	13'
Sand small pea Gravel	NO	13'	20'	7'
Very Fractured Decomposed Granite	NO	20'	40'	20'
Competent Decomposed Granite	NO	40'	55'	15'
solid Granite very little decomposed	Yes	55'	66'	11'

8. WELL CONSTRUCTION
 Depth Drilled 66 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)
 From 6" Inches To 0' Feet 66' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2"</u>		<u>sch 40</u>	<u>0'</u>	<u>45'</u>

Perforations:
 Type perforation Mach. h.c. cut
 Size perforation 020
 From 45 feet to 65 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 40' Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 43' feet to 65' feet

9. WATER LEVEL
 Static water level 49' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature N/A °F Quality N/A

Date started Dec 2, 1900
 Date completed Dec 3, 1900

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Bart Langyear Contractor
 Address P.O. Box 1000 Dayton NV 89403 Contractor
 Nevada contractor's license number 0021976
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2168
 Signed Nathaniel
 By driller performing actual drilling on site or contractor
 Date 12/30/00