

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 83434  
 Permit No. \_\_\_\_\_  
 Basin 61

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43262

OWNER Barrick Goldstrike Mines PZ99-17  
 MAILING ADDRESS P.O. Box 29  
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike  
minesite, north of Carlin, NV.

2. LOCATION NE 1/4 SW 1/4 Sec. 19 T 36N N/S R 50E E Eureka County  
 PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<b>Abandoned by pumping neat cement from T.D. to surface.</b>				
<b>Quantities Used:</b>				
#1: 14 cu.ft.				
#2: 9 cu.ft.				
<b>Original Construction Detail:</b>				
Cement		0	25	25
Hole plug		25	210	185
Gravel		210	242	32
Hole plug		242	343	101
Cement		343	361	18
Hole plug		361	370	9
Gravel		370	410	40

8. WELL CONSTRUCTION  
 Depth Drilled 410 Feet Depth Cased 400 Feet  
**HOLE DIAMETER (BIT SIZE)**  

	From	To
<u>14.750</u> Inches	<u>0</u> Feet	<u>25</u> Feet
<u>8.875</u> Inches	<u>25</u> Feet	<u>410</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10.750</u>	<u>28.04</u>	<u>0.250</u>	<u>0</u>	<u>25</u>
<u>1: 2.375</u>	<u>3.65</u>	<u>0.154</u>	<u>+1</u>	<u>400</u>
<u>2: 2.375</u>	<u>3.65</u>	<u>0.154</u>	<u>+1</u>	<u>240</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 0.125" X 3"  
 From 1: 380 feet to 400 feet  
 From 2: 220 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 25'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From See Detail feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 1: 315.9 2: Dry feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor  
 Address P.O. Box 5279 Contractor

Elko, NV 89802-5279  
 Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1888

Signed David R. Deriot  
 By driller performing actual drilling on-site or contractor

Date 10/23/00

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)

*BST-C*