

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83470
 Permit No. 104
 Basin 104
 NOTICE OF INTENT NO. 45852

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER MARV MCQUARY CONSTRUCTION ADDRESS AT WELL LOCATION LOWES PROJECT
 MAILING ADDRESS 49 INDUSTRIAL PARKWAY 395 & FAIRVIEW
CARSON CITY, NV 89706 CARSON CITY, NV 89701

2. LOCATION SW 1/4 SW 1/4 Sec 17 T 15 N R 20 E CARSON County
 PERMIT NO. 04-012-22 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other N/A

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SET UP OVER OLD 6" FISHED FOR SEVERAL HOURS TRYING TO GET OUT OLD PUMP AND PIPE. WAS UNSUCCESSFUL. WAS ABLE TO HOOK ON TO PIPE BUT BROKE OFF EVEN FURTHER DOWN THE HOLE PLACED TREEMING PIPE TO BOTTOM OF WELL AND PRESSURE PUMPED NEAT CEMENT TO SURFACE		0	58	58
NOTE: TALKED TO MIKE AT STATE OFFICE HE SAID TO PUMP IT WITH CEMENT.				

8. WELL CONSTRUCTION

Depth Drilled N/A Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>6 5/8</u> Inches	<u>0</u> Feet <u>58</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>58</u>

Perforations:

Type perforation N/A
 Size perforation N/A

From	To
<u>N/A</u> feet to	<u>N/A</u> feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal N/A Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From N/A feet to N/A feet

7. WELL TEST DATE

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Date started 3/30, 20 01
 Date completed 3/30, 20 01

9. WATER LEVEL

Static water level 4 feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING
 (CONTRACTOR)
 Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed Michael Z. Heck
 By driller performing actual drilling on site or contractor
 Date 3/30/01