WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83504
Permit No.
Basin 212

1. OWNER BOULDER RUSSELL LLC
MAILING ADDRESS 2700 W SAHARA
LAS VEGAS, NV 89102 %APPLE INVEST INC.

NOTICE OF INTENT NO. ~~21530~~ 21535
ADDRESS AT WELL LOCATION 6451 BOULDER HWY
LAS VEGAS, NV

2. LOCATION NE ¼ NE ¼ Sec. 34 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. DW-1134 Issued by Water Resources
161-34-511-003 Parcel No.
ON TIME CONSTRUCTION Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. D/W PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ABANDON 2 DEWATER WELLS | | | | |
| Pulled casing & drilled out gravel. | | | | |
| Filled each well with 3.5yards of 9 sack sand cement slurry. | | | | |

Date started April 18, 2001, 19
Date completed April 18, 2001, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0' Feet | 30' Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | 36.71 | 0250 | | |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine
Size perforation ~~1/4 x 2 1/2x~~
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 30'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. Contractor
Address 4847 S. VALLEY VIEW Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources/the on-site driller ABDS2161 85
Signed By driller performing actual drilling on site or contractor
Date April 27, 2001

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627