

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 83512  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **44221**

1. OWNER Hillside Dairy ADDRESS AT WELL LOCATION 2505 Schurz Hwy Fallon  
 MAILING ADDRESS 4170 Bass Rd Nv. 89406  
Fallon, NV 89406

2. LOCATION 1/4 1/4 Sec. 7&18 T 18 N/S R 29 E Churchill County  
 PERMIT NO. 00675106 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	18	18
Brown Clay		18	22	4
Brown Sand		22	30	8
Green Sand		30	45	15
Black Sand		45	55	
Black Slit		55	65	10
Black Cla		65	67	2
Black Sand		67	73	6
Black Slit		73	103	30
Brown Clay		103	107	4
Brown Slit		107	115	8
Brown Clay		115	120	5
Brown Sand		120	155	35

8. WELL CONSTRUCTION  
 Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet  
 From 0 Feet To 155 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	15
6 pvc	3.92	.258	15	155

Perforations:  
 Type perforation Saw Cut  
 Size perforation 1/8

From 150 feet to 155 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 155 feet

9. WATER LEVEL  
 Static water level 11 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1264 Contractor  
Fallon Nv. 89407  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Sauer  
 By driller performing actual drilling on-site or contractor  
 Date 05/23/2000

Date started 05/11/2000, 19  
 Date completed 05/15/2000, 19

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		