


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 83558  
 Permit No. \_\_\_\_\_  
 Basin 106  
  
 NOTICE OF INTENT NO. **44919**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Tony & Kathleen Dolce** ADDRESS AT WELL LOCATION **3257 Hyland Way**  
 MAILING ADDRESS **3865 Granite Way** **Hollbrooke Jct.**  
**Wellington, NV 89444**

2. LOCATION **NW** 1/4 **SW** 1/4 Sec. **18** T **10N** N/S R **22E** E **Douglas** County  
 PERMIT NO. **37-502-050** **Hollbrooke Hylands**  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other

4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  Cable  Rotary  RVC  Air  Other **mud**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Andesite sluff some large boulders	no	0	17	17
Andesite sluff small rocks and sand	no	17	67	50
Andesite sluff with large boulders	no	67	158	91
Fractured Andesite with some clay and some sand in the fractures	yes	158	220	62

8. WELL CONSTRUCTION  
 Depth Drilled **220** Feet Depth Cased **220** Feet

HOLE DIAMETER (BIT SIZE)  
 From **10 5/8** Inches To **0** Feet  
 To **220** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>13</b>	<b>.188</b>	<b>+2</b>	<b>220</b>

Perforations:  
 Type perforation **Factory milled**  
 Size perforation **1/8 X 3 6 row**  
 From **200** feet to **220** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet


Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal \_\_\_\_\_  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **50** feet to **220** feet

9. WATER LEVEL  
 Static water level **135** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cold** °F Quality **good**

Date started **6/5/2001**, 19\_\_\_\_  
 Date completed **6/8/2001**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<b>12</b>		<b>2 hrs</b>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Eddco Exploration Inc** Contractor  
 Address **7780 Curry Rd.** Contractor  
**Fallon Nv. 89406**  
 Nevada contractor's license number issued by the State Contractor's Board **27673A**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller \_\_\_\_\_  
 Signed   
 By driller performing actual drilling on-site or contractor  
 Date **6/12/2001**