


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83661
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22253

1. OWNER **PAHRUMP CONCRETE** ADDRESS AT WELL LOCATION 400 SLOAN PAHRUMP
 MAILING ADDRESS 400 SLOAN
PAHRUMP, NV 89048

2. LOCATION NE 1/4 NW 1/4 Sec. 22 T 19S N/S R 53E E NYE County
 PERMIT NO. 29-302-08 **COUNTRY PLACE II**
Issued by Water Resources Parcel No. Subdivision Name

3. **WORK PERFORMED** New Well Replace Recondition Deepen Abandon Other _____
 4. **PROPOSED USE** Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. **WELL TYPE** Cable Rotary RVC Air Other _____

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	8	8
SAND & GRAVEL		8	27	19
CLAY & GRAVEL		27	87	60
CEMENTED GRAVEL		87	98	11
CLAY & GRAVEL		98	148	50
CALICHIE		148	156	8
CLAY		156	187	31
CALICHIE	WB	187	194	7
CLAY		194	213	19
CALICHIE	WB	213	221	8
LOOSE GRAVEL	WB	221	232	11

8. **WELL CONSTRUCTION**
 Depth Drilled 232 Feet Depth Cased 232 Feet
HOLE DIAMETER (BIT SIZE)
 From 10.25 Inches To 0 Feet 232 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	232

Perforations:
 Type perforation **SAW CUT**
 Size perforation **1/8 X 3**
 From 212 feet to 232 feet
 From 172 feet to 192 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 50 _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 232 feet

9. **WATER LEVEL**
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 7/10/2001 .19
 Date completed 7/11/2001 .19

7. **WELL TEST DATA**

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. **DRILLER'S CERTIFICATION**
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor
 Address **P.O. BOX 4220** Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**
 Signed Thomas Dan
 By driller performing actual drilling on-site or contractor
 Date **7/16/01**

