

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44306

1. OWNER Paul Robison ADDRESS AT WELL LOCATION off Red Rock Rd Reno NV 89506
MAILING ADDRESS 2017 Sunburst Reno NV 89509
2. LOCATION NE 1/4 NW 1/4 Sec 4 T 23 S 18 E Washoe County
PERMIT NO. 073-292-20 Parcel No. Rancho Klavin Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	47	47
Clay		47	97	50
Sand		57	100	43
Rock		100	105	5
Clay		105	147	42
Clay & Sandstone		147	191	44
Sandy Clay		191	222	31
Sand		222	235	13
Clay & Sand layers		235	281	46
Coarse Sand		281	298	17

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
From 11 Inches To 0 Feet 300 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>3/16</u>	<u>25</u>	<u>300</u>

Perforations:
Type perforation Saw Slot
Size perforation 3.5 x 3/16
From 220 feet to 240 feet
From 280 feet to 300 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 50 Cement Grout
Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow NO G.P.M. _____ P.S.I. _____
Water temperature Cold °F Quality Good

Date started 6/6/01
Date completed 6/15/01

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>75</u>	<u>180</u>	<u>6</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olenki Drilling & Pump Contractor
Address 15045 Red Rock Rd Reno NV 89506 Contractor
Nevada contractor's license number 50343 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1656
Signed [Signature] By driller performing actual drilling on site or contractor
Date 6/21/01