WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83865
Permit No.
Basin 87

NOTICE OF INTENT NO. 40585

1. OWNER Washoe County Dept. of Water Resources
MAILING ADDRESS 4930 Energy Way
Reno, Nv. 89821

ADDRESS AT WELL LOCATION On Kuenzli Street
Next to Mill

2. LOCATION SE ¼ NE ¼ Sec. 12 T. 19 N/S R. 19 E. Washoe County

PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Gravel with Cobbles		0'	18'	18'
Silty Gravel		18'	19.5'	1.5'
Cobbley Gravel		19.5'	29'	9.5'
Silty Gravel		29'	37.5'	8.5'
Fine Silt		37.5'	42'	4.5'
Gravel with Silt		42'	62'	20'
Coarse Sandstone		62'	63'	1
Gravel with Silty Sand		63'	87'	24'
Gravely Sand		87'	98'	11'
Silty Clay		98'	100'	2'
Sand		100'	107'	7'
Clay - Silty		107'	110'	3'
Silty Clay - Clay		110'	128'	18'
Coarse Sand		128'	129'	1
Cobbles & Silty Clay		129'	130'	1'
Coarse Sand		130	165'	35'
Silty Clay		165'	168'	3'
Medium to Fine Sand		168'	170'	2'
Silty Clay		170'	204'	34'
Silty Sand		204'	227'	23'
Sandy Gravel		227'	248'	21'
Silt with Some Clay		248'	250.5'	2.5'
Sand - Medium		250.5'	253'	2.5'

Date started 4-17-01, 19__
Date completed 4-20-01, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 253' Feet Depth Cased 253' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches		0' Feet	100' Feet
6" Inches		100' Feet	253' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch. 80	0'	251.5'

Perforations:
Type perforation Factory Cut
Size perforation 0.020"
From 251.5' feet to 231.5' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Seal Type:
Depth of Seal 0'-21' Cement Grout 21'-218' Quick Grout 218'-223' Bent. Pellets
☐ Neat Cement
☑ Cement Grout
☐ Concrete Grout
Placement Method: ☑ Pumped ☐ Poured
Gravel Packed: ☑ Yes ☐ No
From 223.4' feet to 251.5' feet

9. WATER LEVEL
Static water level 22' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Phillip Cramer for Boart Longyear (Contractor)
Address 32 Stokes Dr. Dayton, Nv. 89403 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2148
Signed Phillip E. Cramer (By driller performing actual drilling on site or contractor)
Date 5-17-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627