WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83886
Permit No.
Basin 101

NOTICE OF INTENT NO. 43961

1. OWNER Hendrix Properties
MAILING ADDRESS P.O. Box 1687
Fallon, NV 89407

ADDRESS AT WELL LOCATION 2650 Harvey lane,
Fallon, NV 89406

2. LOCATION NW 1/4 NE 1/4 Sec. 22 T 19N N/S R 28E E Churchill County
PERMIT NO. (Issued by Water Resources) 8-081-13 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand		0	8	8
Brown Clay		8	23	15
Brown Sand		23	26	3
Brown Clay		26	29	3
Brown Sand		29	33	4
Brown Clay		33	35	2
Brown Sand		35	47	12
Gray Clay		47	49	2
Gray Sand		49	52	3
Black Sand		52	55	3
Black Clay		55	57	2
Brown Sand		57	60	3
Black Clay		60	64	4
Black Sand		64	75	11
Brown Clay		75	77	2
Brown Sand		77	83	6

RECEIVED
01 JUN -1 AM 11:10
STATE ENGINEER'S OFFICE

Date started 03/15/2001 , 19__
Date completed 03/15/2001 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1hr

8. WELL CONSTRUCTION
Depth Drilled 83 Feet Depth Cased 83 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	83	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	10
6 PVC	3.92	.258	10	83

Perforations:
Type perforation saw cut
Size perforation 1/8
From 80 feet to 83 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 75
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 75 feet to 83 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, for on-site driller 1753
Signed (By driller performing actual drilling on-site or contractor)
Date 03/20/2001

USE ADDITIONAL SHEETS IF NECESSARY