

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 83891  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43949

1. OWNER Eric Sponsler ADDRESS AT WELL LOCATION 4600 Solias Road,  
 MAILING ADDRESS 4600 Solias Road Fallon, NV 89406  
Fallon, NV 89406  
 2. LOCATION SE 1/4 NE 1/4 Sec. 16 T 18N N/S R 28E E Churchill County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources 006-434-01 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gray Sand		0	7	7
Brown Clay		7	12	5
Brown Sand		12	25	13
gray Clay		25	27	2
gray sand		27	30	3
gray clay		30	34	4
gray sand		34	50	16
Gray Clay		50	54	4
gray sand		54	65	11
gray clay		65	75	10
gray sand		75	79	4
gray clay		79	83	4
gray sand		83	98	15
gray clay		98	110	12
gray sand		110	115	5
gray clay		115	123	8
black clay		123	129	6
gray clay		129	133	4
gray sand		133	146	13
black clay		146	152	6
brown clay		152	153	1
Brown Sand		153	160	7

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 Steel	12.92	.188	0	20
6 PVC	3.92	.258	20	160

Perforations:  
 Type perforation saw cut  
 Size perforation 1/8  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 160 feet

9. WATER LEVEL  
 Static water level 3 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1264 Contractor  
Fallon, Nv. 89407  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
 Signed W. J. Parsons  
 By driller performing actual drilling on site or contractor  
 Date 03/15/2001

Date started 03/13/2001, 19\_\_\_\_  
 Date completed 03/14/2001, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30gpm</u>		<u>1hr</u>