WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84017
Permit No. 65639
Basin 202

NOTICE OF INTENT NO. 29586

1. OWNER Ruby Lister
MAILING ADDRESS PO Box 402
Pioche, NV 89043

ADDRESS AT WELL LOCATION SE 1/4 NW 1/4 Sec 22 T2N R67E

2. LOCATION SE 1/4 NW 1/4 Sec. 22 T 2 N/S R 67 E Lincoln County
PERMIT NO. 65639 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	8	8
Sand w/clay		8	120	112
Clay		120	260	140
Clay w/layers of sand		260	320	60
Sand w/layers pea gravel		320	440	120
Clay		440	615	175
Clay w/sand stringers		615	640	25
fine sand w/layers		640	700	60
of gravel/cemented sand				
N38.022262				
W 114.459022 NAD27				

Date started December 21 2000
Date completed June 30 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
800	102	30 hrs

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 702 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
20 Inches		0 Feet	460 Feet
12 Inches		460 Feet	700 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14"		.250	+2	460
10 3/4"		.250	460	700

Perforations:
Type perforation 14" Millslot | 10 3/4" Torch
Size perforation .125" x 4" | 1/4" x 12" 8 lines

From 100 feet to 120 feet
From 200 feet to 220 feet
From 260 feet to 280 feet
From 320 feet to 460 feet
From 10 3/4" - 460 feet to 700 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 700 feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name 8 Mile Drilling (Contractor)
Address PO Box 402 (Contractor)
Pioche, NV 89043
Nevada contractor's license number issued by the State Contractor's Board 0029502
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1441
Signed Wayne Lister (By driller performing actual drilling on site or contractor)
Date July 17, 2001

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627