WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84020
Permit No.
Basin 88

NOTICE OF INTENT NO. 38064

1. OWNER Robert Harmon
MAILING ADDRESS 176 Concho Dr.
Reno, NV 89511

ADDRESS AT WELL LOCATION 176 Concho Dr.

2. LOCATION SW 1/4 SW 1/4 Sec. 7 T 17N N/S R 20E E Washoe County
PERMIT NO. WaCo#6903 (Issued by Water Resources) 050-112-07 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburder		0	4	4
D.G.		4	12	8
Blue rock & clay		12	18	6
Boulders		18	32	14
Fractured granite		32	84	52
Brown Clay		84	106	22
Black fractured Basalt	x	106	117	11
Tan clay		117	183	66
Black basalt w/ tan clay		183	205	22
Tan clay		205	218	13
Fractured granite	x	218	250	32

Date started 7/5/2001, 19__
Date completed 7/13/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
air	25+		2 hours

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4"	Inches	0	Feet	105	Feet
9 7/8"	Inches	105	Feet	250	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	250

Perforations:
Type perforation Factory
Size perforation 3/32 x 3" single row
From 106 feet to 116 feet
From 220 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 0 feet to 100 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 7/17/01

USE ADDITIONAL SHEETS IF NECESSARY