

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 84025
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22684
2650 S LV Blvd.

1. OWNER WELLS CARLO INC. ADDRESS AT WELL LOCATION LV, NV
 MAILING ADDRESS LV, NV

2. LOCATION SE 1/4 NE 1/4 Sec. 9 T. 21 N. R. 61 E CLARK County
 PERMIT NO. DN-11-37 162-09-613-001 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE Dewater
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Remove casing - Vacuum & CLEAN</u>				
<u>Hole from 0 - 10 ft. GRAVITY</u>				
<u>Pool Slurry Mix from 10' to</u>				
<u>surface for seal.</u>				
<u>Procedure used on</u>				
<u>4 WELLS AT this location</u>				
<u>ALL existing wells sealed at</u>				
<u>this location.</u>				

8. WELL CONSTRUCTION
 Depth Drilled 35' Feet Depth Cased 35' Feet

HOLE DIAMETER (BIT SIZE)
 From 24 Inches To 0 Feet 35 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>	<u>PVC</u>	<u>Schd 40</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation Slot
 Size perforation .030
 From 5 feet to 35 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 0-10'
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 10 feet to 35' feet

9. WATER LEVEL
 Static water level: 8' feet below land surface
 Artesian flow: _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality good

Date started 7-31 NOI
 Date completed 7-31 NOI

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GRiffin Dewatering Contractor
 Address 536 E HAITLAND Contractor
ONTARIO Ca. 91761
 Nevada contractor's license number issued by the State Contractor's Board: 0031246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: ABDS-2150
 Signed Edk Jansen
 By driller performing actual drilling on site or contractor
 Date 7-31-01