WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84071
Permit No.
Basin 179
NOTICE OF INTENT NO. 45492

1. OWNER Walter Leineke
MAILING ADDRESS PO Box 971
Reno, NV 89504
ADDRESS AT WELL LOCATION 655 West 244 North Street

2. LOCATION SE ¼ NE ¼ Sec. 21 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. (Issued by Water Resources) Lot 99 APN 5-601-25 (Parcel No.) Cross Timbers (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Sand & Gravel		4	20	16
Clay & Gravel		20	50	30
Sand & Gravel		50	70	20
Clay & Gravel		70	95	25
Clay		95	115	20
Clay with water bearing	X	115		
sand & Gravel Stringers			130	15
Clay		130	155	25
Clay with water bearing	X	155		
sand & Gravel Stringers			170	15
Clay		170	181	11

Date started July 12, 200
Date completed July 16, 200

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	57	1

8. WELL CONSTRUCTION
Depth Drilled 181 Feet Depth Cased 181 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10-5/8	0	181

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	181

Perforations:
Type perforation Factory
Size perforation 1/8" X 2½" 6 Rows
From 100 feet to 181 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 Ft.
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 181 feet

9. WATER LEVEL
Static water level 113 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rick Lewis By Jerald D. Christiansen
By driller performing actual drilling on site or contractor
Date July 19, 2001

01 JUL 23 PM 12:04 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627