


OFFICE USE ONLY
 Log No. 84079
 Permit No. _____
 Basin. 207



NOTICE OF INTENT NO. 45788

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER White Pine School District ADDRESS AT WELL LOCATION Lund, Nevada
 MAILING ADDRESS 1135 Ave C.
Ely, NV 89301

2. LOCATION NW 1/4 NW 1/4 Sec. 34 T 12 N 62 E White Pine County
Lund K-12 School

PERMIT NO. 66855 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvial Gravel & Sand		0	40	40
Boulders		40	45	5
Alluvial Gravel & Sand		45	90	45
Course Gravel		90	100	10
Gravel & Sand		100	130	30
Sand, Gravel & Clay		130	170	40
Water Sand, Gravel	X	170		
with Clay Stringers			181	11
Cemented Sand & Gravel		181	210	29
Clay, Gravel & Sand		210	215	5

8. WELL CONSTRUCTION

Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)
14 Inches 0 From 215 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	17.02	.250	0	215

Perforations:
 Type perforation 60 Slot Wire Wrapped Screen
 Size perforation _____
 From 175 feet to 215 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 120 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No Bentonite Seal 50' to 125'
 From 125 feet to 215 feet Cement Seal 50' to 5'

Date started May 14 2001
 Date completed June 28 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift	95	75	3
Submersible	75	12	3 1/2
Set @ 169 Ft.			

9. WATER LEVEL
 Static water level 125 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 72 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nevada, 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Raid Lewis By: Gerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date July 9, 2001

RECEIVED
 01 JUL 13 AM 10:52
 WATER RESOURCES DIVISION

5H.P.