

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47074

1. OWNER T Troutman ADDRESS AT WELL LOCATION 9th St SILVER SPRINGS, NV  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NW 1/4 Sec 20 T 17 N/S R 25 E County \_\_\_\_\_  
 PERMIT NO. 17-461-14 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material           | Water Strata | From       | To         | Thick-ness |
|--------------------|--------------|------------|------------|------------|
| <u>Sand</u>        |              | <u>0</u>   | <u>40</u>  | <u>40</u>  |
| <u>Sand/CLAY</u>   |              | <u>40</u>  | <u>85</u>  | <u>45</u>  |
| <u>GRAY CLAY</u>   |              | <u>85</u>  | <u>115</u> | <u>30</u>  |
| <u>CLAY/GRAVEL</u> |              | <u>115</u> | <u>125</u> | <u>10</u>  |
| <u>GRAVEL</u>      |              | <u>125</u> | <u>150</u> | <u>25</u>  |

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u>       |                     | <u>.188</u>             | <u>+1</u>   | <u>150</u> |

Perforations:  
 Type perforation Factory milled  
 Size perforation 3/32  
 From 140 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55 FT  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 55 feet to 150 feet

9. WATER LEVEL  
 Static water level 47' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION  
 This well was drilled to the design and depth reported as true to the best of my knowledge.  
Blatt Drilling & Pump Co.  
P.O. Box 1255  
Carson City, NV 89702  
 Name \_\_\_\_\_ Contractor  
 Address \_\_\_\_\_ Contractor

Date started 18 JUN 2001 19 \_\_\_\_\_  
 Date completed 20 JUN 2001 19 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>25+</u> |                               | <u>1.5</u>   |

Nevada contractor's license number issued by the State Contractor's Board 46491  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Dotson  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_