WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84098
Permit No.
Basin 85

NOTICE OF INTENT NO. 34505

1. OWNER Gray Bergin
MAILING ADDRESS 68 Amigo Ct.
Sparks, NV 89436

ADDRESS AT WELL LOCATION 68 Amigo Ct.
Sparks, NV 89436

2. LOCATION SW ¼ SE ¼ Sec. 18 T. 21 N/S R. 21 E. Washoe County
PERMIT NO. 006604 (Issued by Water Resources) 076-360-57 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	1	1
Granite		1	90	89
Broken Granite		90	149	59
DG Soft		149	308	159
Broken Granite Brown		308	401	93
Broken Granite White		401	590	189
Granite Hard White		590	690	100
Black Lava Basalt		690	715	25
Round Granite Gravel		715	730	15
Granite Broken		730	750	20

Date started July 25, 2001, 19XX
Date completed August 6, 2001, 19XX

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 750 Feet Depth Cased 750 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	Feet	0	60 Feet
8 5/8 Inches	Feet	60	750 Feet
Inches	Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	750

Perforations:
Type perforation Factory
Size perforation 1/8"
From 690 feet to 730 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 580 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Frank Turner (Contractor)
Address 472-205 Johnstonville Rd. (Contractor)
Susanville, CA 96130
Nevada contractor's license number issued by the State Contractor's Board 41661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2037
Signed Turner Drilling & Pump
By driller performing actual drilling on site or contractor
Date August 10, 2001

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627