WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41103
Permit No.
Basin 105

NOTICE OF INTENT NO. 44921

1. OWNER Elton Crowley
MAILING ADDRESS 790 Pawnee
Minden, NV 89423

ADDRESS AT WELL LOCATION 790 Pawnee Minden, Nv.

2. LOCATION SE 1/4 NE 1/4 Sec. 12 T 14N N/S R 19E E Douglas County
PERMIT NO. Issued by Water Resources | 13-080-28 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
No circulation no	no	160		
returns hard frctured				
granite			280	120
		280		
set up on old well and remove 4" liner and deepen				
to 280 ft. Lost circulation at 175 FT.drilled				
blind to 280 ft. and set test pump well making				
very little water and lots of sand Move to new				
well site				

Date started 7/2/2001 , 19__
Date completed 7/12/2001 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
sandy	3		3hrs

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	160	Feet	280	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	160	280

Perforations:
Type perforation factory milled
Size perforation 1/8 x 3 6 row
From 240 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal N/A
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality sandy

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eddco Exploration Inc.
Contractor
Address 7780 Curry road
Contractor
Fallon, Nv. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed
By driller performing actual drilling on-site or contractor
Date 8/4/2001

USE ADDITIONAL SHEETS IF NECESSARY