WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84156
Permit No.
Basin 97-A

NOTICE OF INTENT NO. 45063

1. OWNER R.C. BARNES/WHOLEY CONSTRUCTION
MAILING ADDRESS P.O. BOX 60412
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 11000 Osage
Reno, Nevada 89506

2. LOCATION SE ¼ SE ¼ Sec. 24 T. 21N N/S R. 18 E. Washoe County

PERMIT NO. (Issued by Water Resources) | 086-110-10 (Parcel No.) | Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	16	15
Brown sand		16	18	2
Brown sandy clays		18	49	31
Brown granite sands		49	51	2
Soft clays & sands, some gravel		51	105	54
Brown clays		105	131	26
Med to coarse sands, clay streaks	X	131	144	13
Soft sandy clays		144	151	7

Date started June 25, 2001, 19
Date completed June 25, 2001, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION
Depth Drilled 151 Feet Depth Cased 151 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	151	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	151

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 126 feet to 146 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 151 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow G.P.M. 15 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 12626
Signed Gary G. Hedman (By driller performing actual drilling on site or contractor)
Date June 26, 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627