WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84182
Permit No.
Basin 107

NOTICE OF INTENT NO. 45421

1. OWNER Kevin Rogers
MAILING ADDRESS P.O. Box 271 Smith Nev. 89430
ADDRESS AT WELL LOCATION Lot 32 Sierra Desert View Smith Nev. 89430

2. LOCATION SW ¼ SW ¼ Sec. 15 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. Issued by Water Resources
Parcel No. 9-161-02
Subdivision Name Sierra Desert View Estates

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil sandy loam		0	55	55
sandy clay		55	70	15
sharp gravel + sand	yes	70	95	25
sand + brown clay		95	120	25
pea gravel + sand with some clay seams inbetween	yes	120	150	60

Date started ~~Aug 14~~ Aug 9 01
Date completed Aug 14 01

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
~~8 Hrs~~	30	95	8 Hrs

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 Inches		50 Feet	150 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	150

Perforations:
Type perforation Factory saw slott
Size perforation 3/16 X 3
From 150 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling (Contractor)
Address P.O. Box 92 Smith Nev 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date Aug 21 01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627