



WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 49742  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

m/o 384305-2  
PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15676

1. OWNER SANTA FE PACIFIC GOLD ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 861 W 6<sup>th</sup> ST. WYON. WY. 89443  
 2. LOCATION NW 1/4 NE 1/4 Sec 5 T 38 R 43 E Humboldt County  
 PERMIT NO. m/o 933 Parcel No. 7-131-03 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material                           | Water Strata | From       | To         | Thick-ness |
|------------------------------------|--------------|------------|------------|------------|
| <u>Alluvium CLAY, SAND, GRAVEL</u> |              | <u>0</u>   | <u>160</u> | <u>160</u> |
| <u>SAND PACKED</u>                 |              | <u>160</u> | <u>12</u>  | <u>148</u> |
| <u>3/4" BEANSIZE PELLETS</u>       |              | <u>12</u>  | <u>10</u>  | <u>2</u>   |
| <u>NEAT Cement</u>                 |              | <u>10</u>  | <u>0</u>   | <u>10</u>  |

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 160 Feet  
6 1/2 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2.5</u>         | <u>SCH 80</u>       | <u>P.U.C BLACK</u>      | <u>0</u>    | <u>40</u> |

Perforations:  
 Type perforation 2.5 SCH 80 P.U.C Screen  
 Size perforation .020  
 From 40 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 10'  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 12 feet to 160 feet

9. WATER LEVEL  
 Static water level 98' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRANK DRILLING  
 Contractor  
 Address P.O. Box 2786 ELKO NV. 89803  
 Contractor

Date started 6-18- 1995  
 Date completed 6-19 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

|            | G.P.M.   | Draw Down (Foot Below Static) | Time (Hours) |
|------------|----------|-------------------------------|--------------|
| <u>100</u> | <u>3</u> |                               | <u>1/2</u>   |

Nevada contractor's license number issued by the State Contractor's Board: 0030823  
0619378  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1788  
 Signed John Wells  
 By driller performing actual drilling on site or contractor  
 Date 6-19-95

USE ADDITIONAL SHEETS IF NECESSARY

RIB 384305-2