

m/d 384305-85
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15684

1. OWNER SANTA FE PACIFIC GOLD ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 861 W. 6th ST.
WINN. NV. 89443
 2. LOCATION SE 1/4 SE 1/4 Sec 5 T 38 N 43 E Humboldt County _____
 PERMIT NO. m/d 933 7-131-03 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ALLUVIUM</u>				
<u>CLAY SAND GRAVEL</u>		<u>0</u>	<u>40</u>	<u>40</u>
<u>SAND PACKED</u>		<u>40</u>	<u>12</u>	<u>28</u>
<u>BEANS W/TE PELLETS</u>		<u>12</u>	<u>10</u>	<u>2</u>
<u>NEAT CEMENT</u>		<u>10</u>	<u>0</u>	<u>10</u>

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6.5 Inches To 0 Feet 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>	<u>SCH 80</u>	<u>P.V.C BLANK</u>	<u>0</u>	<u>15</u>

Perforations:
 Type perforation 2.5 sch 80 P.V.C. S&P
 Size perforation .020
 From 15 feet to 40 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 10' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 12 feet to 40 feet

9. WATER LEVEL
 Static water level 4' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EKLUND DRILLING Contractor
 Address P.O. Box 2786 ELKO NV. 89803 Contractor

Date started 6-20, 1995
 Date completed 6-21, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>4</u>	<u>1/2</u>

Nevada contractor's license number issued by the State Contractor's Board 0019374 0030823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1288
 Signed John Welch
 By driller performing actual drilling on site or contractor
 Date 6-21-95